


**NOTES:**

- \* BOTH RISER PIPE AND INSERT PIPE CAN BE EXTENDED--CONTACT MANUFACTURER.
- 1. THREADED PLUG, FEMALE ADAPTER, INSERT PIPE, AND RISER PIPE MAY BE SUPPLIED BY OTHERS.
- 2. BACKFLOW PREVENTER SHALL BE LOCATED FROM HOUSE BETWEEN 2' TO 4'.
- 3. BACKFLOW PREVENTER VALVE SHALL BE A CLEAN CHECK, INC. MODEL #: EBV-P401 OR EQUIVALENT.



# CITY OF EDMONDS

REVISIONS		STANDARD DETAIL		
APPROVED BY	DATE	SIDE SEWER BACKFLOW PREVENTER		
		DATE	SCALE	DWG NO.
		4/2/07	NTS	E6.10